EMERGENCY LIGHTING
TEST RECORD

State of N.J. Uniform Fire Safety Code File 604.3.1.1 requires that all emergency lighting equipment be functionally tested every 30 days for a minimum of 30 seconds and tested yearly for 60 minutes. Written records of testing are to be kept for examination by the authority having jurisdiction. The test record provided may be used to record test results. Make additional copies as required. Record the catalog number of the equipment in the space provided.

TEST RECORD DATE: _____ MONTHLY □ YEARLY □

Emergency Light Unit #	Exit Sign Unit #	TEST DURATION		TEST RESULTS INDICATE OK OR NOT OK(IF NOT OK, DESCRIBE FAILURE)	CORRECTIVE ACTION TAKEN: (EXAMPLE:REPLACED LAMP OR BATTERY, ETC.)
		30 SECOND (Monthly)	60 Minute (Yearly)		

EM = Emergency Light

EX = Exit Sign

PAGE _____ OF _____ Inspected By: _____ Date: _____